

ENGLISH VERSION OF THE OFFICIAL FRENCH PROCÈS-VERBAL N° EFR-25-000586 – Révision 1

**Only the original French edition of this procès-verbal is authentic.
Seule l'édition originale en français du présent procès-verbal fait foi.**

The French PROCES VERBAL is valid for 5 years starting on March 12th, 2025

This report cancels and replaces the English version of the official French procès-verbal n°EFR-25-000586

Version	Modification	Comment	Date		
0	Document creation	/	14/04/2025	Editor	L. BARBIER
				Verifier	L. RODIER
				Approver	L. RODIER
1	Consideration of tests after accelerated ageing test	/	11/07/2025	Editor	L. BARBIER
				Verifier	L. RODIER
				Approver	L. RODIER

Applicant

ANADOLU BAKIR ANONIM SIRKETI
Velimese Osb mah. 3. Yanyol cad. No: 7
ERGENE
TEKIRDAG
Turkey

VAT number

068 090 5728

Sample reference

OTTOCOOL PE FOAM INSULATION PIPE

Brief description provided by the applicant

Expanded polyethylene foam core coated with polyethylene with surface fire-retardant varnish on the outside.
The tubes have an external diameter of 29 mm and an internal diameter of 13 mm.

Density determined by the laboratory

31 kg/m³ ± 10%

Thickness measured by the laboratory

8 mm ± 10%

Colour

White

End-use condition

Insulation for copper pipes

Standard of tests:

- **NF P 92-507 (2004)** - Building - Interior fitting materials - Classification according to their reaction to fire
- **NF P 92-501 (1995)** - Reaction to fire tests Radiation test used for rigid materials, or for materials on rigid substrates (flooring and finishes) of all thicknesses, and for flexible materials thicker than 5 mm
- **NF P 92-512 (1986)** - Reaction to fire tests - Determination of the durability of the fire reaction classification of materials

Classification obtained in the official Procès Verbal:

M1

Valid for any application for which the product is not subjected to the CE marking.

Durability of the classification (NFP 92-512: 1986): Supposedly unlimited

Nota. - Full reproductions and photocopies of this English abstract of the official *procès verbal* of classification or the English version of the official *procès verbal* and the attached tests report are authorized.

Taking into account the criteria resulting from the tests described in the test reports n°EFR-25-000586-EPI from March 14th, 2025 and n°EFR-25-001563-EPI from July 11th, 2025.

This test report only demonstrates the characteristics of the test sample and does not prejudice the characteristics of similar products. It does not provide a certification of products within the Article L.433-3 of the Consumer Code and the Law of June 3rd, 1994.

Efectis France is approved for fire reaction tests according to the Decree of December 29th, 2016 amending the Decree of February 5th, 1959.

Saint-Aubin, on July 11th, 2025